

From: William Haskell <WHaskell@gorrillpalmer.com>
Sent: Wednesday, November 16, 2016 7:34 PM
To: Amanda L. Lessard
Subject: RE: 3200.02 The Plaza - Review of Final Plan Submittal received on 11/14/16

Hi Amanda,

The question 2 in the response is not what I asked. My question/comment regarding the water was as follows:

Related to the retaining wall, consideration should be given to the location of the termination of the 8" water service for extension to the future development.

This was more for their consideration and the proposed future development as the water line appears to dead end at the back of the retaining wall. I'm fine with their other responses.

Thanks,

Will Haskell | Principal



207.772.2515 (office)
207.318.7052 (mobile)

From: Amanda L. Lessard [<mailto:allessard@windhammaine.us>]
Sent: Wednesday, November 16, 2016 1:40 PM
To: William Haskell <WHaskell@gorrillpalmer.com>
Subject: RE: 3200.02 The Plaza - Review of Final Plan Submittal received on 11/14/16

Will,
I just received the attached response to your comments below. I'm going to give you a call to discuss.
Thanks,
Amanda

Amanda Lessard, Planner
Town of Windham
8 School Road
Windham, ME 04062

office: (207) 894-5900 x 6121
cell: (207) 400-7618
fax: (207) 892-1916
www.windhammaine.us

NOTICE: Under Maine's Freedom of Access ("Right to Know") law, documents – including emails – in the possession of public officials about town business are considered public records. This means if anyone asks to see